E2EC

High-sensitivity DC 2-Wire Sensors and Subminiature Sensors with Long-distance Detection

- Shielded Sensor Heads from 3-mm to M12 diameters that can be embedded in metal.
- Robotics cables provided as a standard feature (DC 2-Wire Models).
- Indicator provided in Amplifier cable for easy confirmation of operation.
- Power supply range of 5 to 24 VDC for DC 3-Wire Models.



Be sure to read *Safety Precautions* on page 6.

Ordering Information

Sensors

DC 2-Wire Models

Appearance		Sensing d	istance	Model Operation mode	
				NO	NC
	3 dia. *	0.8 mm		E2EC-CR8D1	E2EC-CR8D2
Shielded	5.4 dia. *	1.5 mm		E2EC-C1R5D1	E2EC-C1R5D2
——	8 dia. *	3 mm		E2EC-C3D1	E2EC-C3D2
<i>V/A</i>	M12 *	4 mm		E2EC-X4D1	E2EC-X4D2

^{*} Models with different frequencies are also available. The model numbers are E2EC-\(\sigma \supers \supers \sigma \supers \text{(example: E2EC-CR8D15)}.\)

DC 3-Wire Models

Annogranos		Sensing distance		Model	
Appea	Appearance		starice	Output configuration	NO
Shielded	3 dia. *	0.5 mm		NPN open collector output	E2EC-CR5C1
—	8 dia. *	2.5 mm		NPN open-collector output	E2EC-C2R5C1

^{*} Models with different frequencies are also available. The model numbers are E2EC-□□□□5 (example: E2EC-CR5D15).

Accessories (Order Separately)

Mounting Bracket

Appearance	Model	Applicable Sensors
	Y92E-F5R4	E2EC-C1R5D□ (5.4-mm-dia. Sensor)



Ratings and Specifications

		DC 2-Wire Models				DC 3-Wire Models		
Item	Model	E2EC-CR8D□	E2EC-C1R5D	E2EC-C3D□	E2EC-X4D□	E2EC-CR5C1	E2EC-C2R5C1	
Sensing d		0.8 mm ±15%	1.5 mm ±10%	3 mm ±10%	4 mm ±10%	0.5 mm ±15%	2.5 mm ±10%	
Set distan		0 to 0.56 mm	0 to 1.05 mm	0 to 2.1 mm	0 to 2.8 mm	0 to 0.3 mm	0 to 1.7 mm	
Differentia		10% max. of sensir		0 10 211 111111	0 10 210 111111	0 10 010 11111	0 10 111 11111	
Detectable object Ferrous metal (The sensing distance decreases with non-ferrous metal. Refer to					Engineering Data	on page 3.)		
	Standard sensing bject $Iron, 5 \times 5 \times 1 \text{ mm}$ $Iron, 8 \times 8 \times 1 \text{ mm}$ $Iron, 12 \times 12 \times 1 \text{ mm}$			Iron,	Iron, $5 \times 5 \times 1$ mm			
Response *	ponse frequency 1.5 kHz 1 kHz							
Power sup age (opera age range)	ting volt-	12 to 24 VDC (10 to	o 30 VDC), ripple (p	-p): 10% max.		5 to 24 VDC (4.75 ripple (p-p): 10% m		
Current consumpt	ion		-			10 mA max.		
Leakage c	urrent	0.8 mA max.				-		
Control	Load current	5 to 100 mA				NPN open-collecto 100 mA max. (30 V		
output	Residual voltage	3 V max. (Load cur	rent: 100 mA, Cable	length: 2 m)		1 V max. (Load cur Cable length: 2 m)	rrent: 100 mA,	
Indicators		D1 Models: Operation indicator (red), Setting indicator (green) D2 Models: Operation indicator (red)			Detection indicator (red)			
Operation (with sens approachi	ing object	object D2 Models: NC Refer to the timin			NO Refer to the timing Circuit Diagrams of			
Protection	circuits	Load short-circuit protection, Surge suppressor				Surge suppressor		
Ambient temperatu	re range	Operating/Storage: -25 to 70°C (with no icing or condensation)						
Ambient humidity r	ange	Operating/Storage:	35% to 95% (with r	o condensation)				
Temperatuinfluence	ire	±20% max. of sens	ing distance at 23°C	in the temperature	range of –25 to 70°C			
Voltage in	fluence	±2.5% max. of sens	sing distance at rate	d voltage in the rate	d voltage ±15%	±5% max. of sensil rated voltage range range of 4.75 to 30	e in the voltage	
Insulation resistance		50 M Ω min. (at 500	VDC) between curr	ent-carrying parts a	nd case			
Dielectric	strength	1,000 VAC for 1 mi	n between current-c	arrying parts and ca	se	500 VAC for 1 min carrying parts and		
Vibration r	esistance	Destruction: 10 to 5	55 Hz, 1.5-mm doub	le amplitude for 2 ho	urs each in X, Y, an	d Z directions		
Shock res	istance	Destruction: 1,000 m/s² 10 times each in X, Y, and Z directions Destruction: X, Y, and Z directions					/s² 10 times each ir ons	
Degree of	protection	IEC 60529 IP67, in-house standards: oil-resistant				IEC 60529 IP64		
Connection method Pre-wired Models (Standard cable length: 2 m)								
Weight (packed st	ate)	Approx. 45 g						
	Case	Brass						
Materials	Sensing surface	ABS						
Accessori	es	Amplifier Mounting	Bracket, Instruction	manual		Instruction manual		
The respons	e frequency is	s an average value.				 		


* The response frequency is an average value.

Measurement conditions are as follows: standard sensing object, a distance of twice the standard sensing object, and a set distance of half the sensing distance.


Engineering Data (Typical)

Sensing Area


E2EC-CR8D1




E2EC-C1R5D1




E2EC-C3D1




E2EC-X4D1



E2EC-CR5C1




E2EC-C2R5C1




Influence of Sensing Object Size and Material


E2EC-CR8D1




E2EC-C1R5D1




E2EC-C3D1




E2EC-X4D1



E2EC-CR5C1




E2EC-C2R5C1




Residual Output Voltage

DC 2-Wire Models



Leakage Current

E2EC



http://www.ia.omron.com/

I/O Circuit Diagrams

DC 2-Wire Models

Operation	Model	Timing Chart	Output circuit
NO	E2EC-CR8D1 E2EC-C1R5D1 E2EC-C3D1 E2EC-X4D1	Non-sensing area area Sensing object (%) 100 70(TYP) 0 Rated sensing distance ON OFF (green) ON OPeration indicator (red) ON Control output	Prox- inity Sensor main circuit
NC	E2EC-CR8D2 E2EC-C1R5D2 E2EC-C3D2 E2EC-X4D2	Non-sensing area Sensing object (%) 100 0 Rated sensing distance ON Operation OFF indicator (red) ON Control OFF output	Note: The load can be connected to either the +V or 0 V side.

DC 3-Wire Models

Operation	Model	Timing Chart	Output circuit
INIC)	E2EC-CR5C1 E2EC-C2R5C1	Sensing Present object Not present Output transistor ON (load) OFF Detection ON indicator (red) OFF	Proximity Sensor main circuit Maximum load current: 100 mA Note: The Sensor may be destroyed if mistakes are made in wiring.

Safety Precautions

Refer to Warranty and Limitations of Liability.



This product is not designed or rated for ensuring safety of persons either directly or indirectly. Do not use it for such purposes.




Precautions for Correct Use

Do not use this product under ambient conditions that exceed the ratings.

Design

Influence of Surrounding Metal

When mounting the Sensor within a metal panel, ensure that the clearances given in the following table are maintained. Failure to maintain these distances may cause deterioration in the performance of the Sensor.



Influence of Surrounding Metal

(Unit: mm)

Model Item	I	d	D	m	n
E2EC-CR8D□		3		2.4	6
E2EC-C1R5D		5.4		4.5	10.8
E2EC-C3D□	0	8	0	9	16
E2EC-X4D	0	12		12	24
E2EC-CR5C1		3		1.5	5
E2EC-C2R5C1		8		10	21

Mutual Interference

When installing Sensors face-to-face or side-by-side, ensure that the minimum distances given in the following table are maintained.





Mutual Interference


(Unit: mm)

Model Item	Α	В
E2EC-CR8D□	18 (4)	6 (3)
E2EC-C1R5D□	15 (8)	10.8 (5.4)
E2EC-C3D□	30 (15)	16 (8)
E2EC-X4D□	40 (20)	24 (12)
E2EC-CR5C1	20 (10)	15 (3)
E2EC-C2R5C1	40 (20)	25 (15)

Note: Values in parentheses apply to Sensors operating at different frequencies.

Mounting

 Refer to the following table for the torque and tightening ranges applied to mount the E2EC-C Unthreaded Cylindrical Model. Tightening must be as given in the following table.



Permissible Tightening Range and Torque

Model	Tightening	Set screw tightening	
E2EC-CR8D□	6 to 10 mm	0.49 N·m	
E2EC-C1R5D	8 to 16 mm	0.49 (0.11)	
E2EC-C3D□	8 10 16 111111	0.98 N·m	
E2EC-CR5C1	6 to 16 mm	0.39 N·m	
E2EC-C2R5C1	8 to 16 mm	0.39 11.111	

 The tightening torque applied to the E2EC-X4D□ Threaded Cylindrical Models must be 12 N·m max.




Amplifier Mounting Bracket for DC 2-Wire Models Mounting

1. Insert the Amplifier into the trapezoidal end (i.e., the fixing side) of the Mounting Bracket.




2. Press the other end of the Amplifier onto the Bracket.



Dismounting

Lightly press the hook on the Mounting Bracket with a flat-blade screwdriver



2. The Amplifier will be automatically released due to the spring force of the Mounting Bracket.




Dimensions (Unit: mm)


Main Units

E2EC-CR8D With Mounting Bracket Attached 2.9-dia. vinyl-insulated round robotics cable with 2 conductors (Conductor cross section: 0.15 mm², Insulator diameter: 1 mm), 1.6-dia shielded robotics cable, Standard length: 400 mm Standard length: 2 m 25.5 Indicators *2 *1. The cable can be extended up to 200 m 10.3 (separate metal conduit). *2. D1 Models: Operation indicator (red), Setting indicator (green) D2 Models: Operation indicator (red) wo, 3.2-dia. mounting holes Nounting Bracket


E2EC-C1R5D




With Mounting Bracket Attached



E2EC-C3D




With Mounting Bracket Attached



E2EC-X4D



With Mounting Bracket Attached




Mounting Hole Dimensions




Model	F (mm)
E2EC-CR8D□	3.3 ^{+0.3} dia.
E2EC-C1R5D□	5.7 ^{+0.3} dia.
E2EC-C3D□	8.5 +0.5 dia.
E2EC-X4D□	12.5 ^{+0.5} ₀ dia.

E2EC-CR5C1






- *1. 4-dia. vinyl-insulated round cable with 3 conductors (Conductor cross section: 0.2 mm², Insulator diameter: 1.2 mm), Standard length: 2 m *2. The cable can be extended up to 50 m (separate metal conduit). *3. 1.2-dia shielded cable, Standard length: 400 mm




Mounting Hole Dimensions




E2EC-C2R5C1






- *1. 4-dia. vinyl-insulated round cable with 3 conductors (Conductor cross section: 0.2 mm², Insulator diameter: 1.2 mm),
- υ.∠ πιπ', insulator diameter: 1.2 mm), Standard length: 2 m
 *2. The cable can be extended up to 50 m (separate metal conduit).
 *3. 2.5-dia shielded cable, Standard length: 400 mm









Mounting Hole Dimensions




Model	F (mm)
E2EC-CR5C1	3.3 +0.3 dia.
E2EC-C2R5C1	8.5 +0.5 dia.

Mounting Bracket








Accessories (Order Separately)

Mounting Bracket (for 5.4 dia.)

Y92E-F5R4



Material: Stainless steel (SUS304) Note: Used for E2EC-C1R5D□ Head.



http://www.ia.omron.com/

General Precautions For precautions on individual products, refer to the Safety Precautions in individual product information.

WARNING

These products cannot be used in safety devices for presses or other safety devices used to protect human life.



These products are designed for use in applications for sensing workpieces and workers that do not affect safety.

Precautions for Safe Use

To ensure safety, always observe the following precautions.

Wiring Considerations

Typical examples DC 3-Wire NPN Output Sensors DC 2-Wire Sensors **Power Supply Voltage** Do not use a voltage that exceeds the operat-Load ing voltage range. Applying a voltage that is Brown Load higher than the operating voltage range, or us-Brown ing an AC power supply (100 VAC or higher) for a Sensor that requires a DC power supply may cause explosion or burning. Load short-circuiting DC 3-Wire NPN Output Sensors • DC 2-Wire Sensors • Even with the load short-circuit protection . Do not short-circuit the load. Explosion or function, protection will not be provided when burning may result. a load short circuit occurs if the power supply • The load short-circuit protection function oppolarity is not correct. erates when the power supply is connected with the correct polarity and the power is Load within the rated voltage range. (Load short circuit) Load Black circuit) Senso Blue Blue **Incorrect Wiring** DC 3-Wire NPN Output Sensors Be sure that the power supply polarity and oth-Load er wiring is correct. Incorrect wiring may cause explosion or burning. Brown Brown Black Blue Blue **Connection without a Load** • DC 2-Wire Sensors AC 2-Wire Sensors Even with the load short-circuit protection If the power supply is connected directly withfunction, protection will not be provided if out a load, the internal elements may explode both the power supply polarity is incorrect or burn. Be sure to insert a load when connectand no load is connected. ing the power supply.

Operating Environment

Do not use the Sensor in an environment where there are explosive or combustible gases.

Brown


Blue

Brown Senso

Precautions for Correct Use

The following conditions must be considered to understand the conditions of the application and location as well as the relation to control equipment.

Model Selection




 $^{^{\}star}$ mT (millitesla) is a unit for expressing magnetic flux density. One tesla is the equivalent of 10,000 gauss.

●Design

Sensing Object Material

The sensing distance varies greatly depending on the material of the sensing object. Study the engineering data for the influence of sensing object material and size and select a distance with sufficient leeway.


 In general, if the sensing object is a nonmagnetic metal (for example, aluminum), the sensing distance decreases.



Size of Sensing Object


In general, if the object is smaller than the standard sensing object, the sensing distance decreases.


- Design the setup for an object size that is the same or greater than the standard sensing object size from the graphs showing the sensing object size and sensing distance.
- When the size of the standard sensing object is the same or less than the size of the standard sensing object, select a sensing distance with sufficient leeway.



Thickness of Sensing Object

- The thickness of ferrous metals (iron, nickel, etc.) must be 1 mm or greater.
- When the coating thickness is 0.01 mm or less, a sensing distance equivalent to a magnetic body can be obtained. When the coating is extremely thin and is not conductive, such as a vacuum deposited film, detection is not possible.





Effect of Plating (Typical)

(Reference values: Percent of non-plated sensing distance)

Thickness and base material of plating	Steel	Brass
No plating	100	100
Zn 5 to 15 μm	90 to 120	95 to 105
Cd 5 to 15 μm	100 to 110	95 to 105
Ag 5 to 15 μm	60 to 90	85 to 100
Cu 10 to 20 μm	70 to 95	95 to 105
Cu 5 to 15 μm	-	95 to 105
Cu (5 to 10 μ m) + Ni (10 to 20 μ m)	70 to 95	-
Cu (5 to 10 μm) + Ni (10 μm) + Cr (0.3 μm)	75 to 95	-

Mutual Interference

- Mutual interference refers to a state where a Sensor is affected by magnetism (or static capacitance) from an adjacent Sensor and the output is unstable.
- One means of avoiding interference when mounting Proximity Sensors close together is to alternate Sensors with different frequencies. The model tables indicate whether different frequencies are available. Please refer to the tables.
- When Proximity Sensors with the same frequency are mounted together in a line or face-to-face, they must be separated by a minimum distance. For details, refer to *Mutual Interference* in the Safety Precautions for individual Sensors.

Power Reset Time

A Sensor is ready for detection within 100 ms after turning ON the power. If the load and Sensor are connected to separate power supplies, design the system so that the Sensor power turns ON first.

Turning OFF the Power

An output pulse may be generated when the power is turned OFF, so design the system so that the load or load line power turns OFF first.

Influence of Surrounding Metal

The existence of a metal object other than the sensing object near the sensing surface of the Proximity Sensor will affect detection performance, increase the apparent operating distance, degrade temperature characteristics, and cause reset failures. For details, refer to the influence of surrounding metal table in *Safety Precautions* for individual Sensors.

The values in the table are for the nuts provided with the Sensors. Changing the nut material will change the influence of the surrounding metal.

Power Transformers

Be sure to use an insulated transformer for a DC power supply. Do not use an auto-transformer (single-coil transformer).

Precautions for AC 2-Wire/DC 2-Wire Sensors

Surge Protection

Although the Proximity Sensor has a surge absorption circuit, if there is a device (motor, welder, etc.) that causes large surges near the Proximity Sensor, insert a surge absorber near the source of the surges.

Influence of Leakage Current

Even when the Proximity Sensor is OFF, a small amount of current runs through the circuit as leakage current.

For this reason, a small current may remain in the load (residual voltage in the load) and cause load reset failures. Verify that this voltage is lower than the load reset voltage (the leakage current is less than the load reset current) before using the Sensor.

Using an Electronic Device as the Load for an AC 2-Wire Sensor

When using an electronic device, such as a Timer, some types of devices use AC half-wave rectification. When a Proximity Sensor is connected to a device using AC half-wave rectification, only AC half-wave power will be supplied to the Sensor. This will cause the Sensor operation to be unstable. Also, do not use a Proximity Sensor to turn the power supply ON and OFF for electronic devices that use DC half-wave rectification. In such a case, use a relay to turn the power supply ON and OFF, and check the system for operating stability after connecting it.

Examples of Timers that Use AC Half-wave Rectification Timers: H3Y, H3YN, H3RN, H3CA-8, RD2P, and H3CR (-A, -A8, -AP, -F, -G)

http://www.ia.omron.com/

Countermeasures for Leakage Current (Examples)

AC 2-Wire Sensors

Connect a bleeder resistor to bypass the leakage current flowing in the load so that the current flowing through the load is less than the load reset current.

When using an AC 2-Wire Sensor, connect a bleeder resistor so that the Proximity Sensor current is at least 10 mA, and the residual load voltage when the Proximity Sensor is OFF is less than the load reset voltage.



Calculate the bleeder resistance and allowable power using the following equation.

$$R \le \frac{Vs}{10 - I} (k\Omega)$$
 $P > \frac{Vs^2}{R} (mW)$


P : Watts of bleeder resistance (the actual number of watts used should be several times this number)

I : Load current (mA)

It is recommend that leeway be included in the actual values used. For 100 VAC, use 10 k Ω or less and 3 W (5 W) or higher, and for 200 VAC, use 20 k Ω or less and 10 W (20 W) or higher. If the effects of heat generation are a problem, use the number of watts in parentheses () or higher.

DC 2-Wire Sensors

Connect a bleeder resistor to bypass the leakage current flowing in the load, and design the load current so that (leakage current) \times (load input impedance) < reset voltage.



Calculate the bleeder resistance and allowable power using the following equation.

$$R \leq \frac{Vs}{-i_R - i_{OFFR}} (k\Omega) \qquad \qquad P > \frac{Vs^2}{-R} (mW)$$

P : Watts of bleeder resistance (the actual number of watts used should be several times this number)

in : Leakage current of Proximity Sensor (mA)

ioff: Load reset current (mA)

It is recommend that leeway be included in the actual values used. For 12 VDC, use 15 $k\Omega$ or less and 450 mW or higher, and for 24 VDC, use 30 $k\Omega$ or less and 0.1 W or higher.

Loads with Large Inrush Current

Loads, such as lamps or motors, that cause a large inrush current* will weaken or damage the switching element. In this situation, use a

* E2K, TL-N□Y: 1 A or higher

Mounting

Mounting the Sensor

When mounting a Sensor, do not tap it with a hammer or otherwise subject it to excessive shock. This will weaken water resistance and may damage the Sensor. If the Sensor is being secured with bolts, observe the allowable tightening torque. Some models require the use of toothed washers.


For details, refer to the mounting precautions in Precautions for Correct Use in individual product information.

Mounting/Removing Using DIN Track

(Example for E2CY)

<Mounting>

- (1)Insert the front of the Sensor into the special Mounting Bracket (included) or DIN Track.
- (2) Press the rear of the Sensor into the special Mounting Bracket or DIN Track.



DIN Track (or Mounting Bracket)


• When mounting the side of the Sensor using the special Mounting Bracket, first secure the Amplifier Unit to the special Mounting Bracket, and then mount the special Mounting Bracket with M3 screws and flat washers with a diameter of 6 mm maximum.



Flat washers (6 dia. max.)

<Removing>

• While pressing the Amplifier Unit in the direction of (3), lift the fiber plug in the direction of (4) for easy removal without a screwdriver.



Set Distance

The sensing distance may vary due to fluctuations in temperature and voltage. When mounting the Sensor, it is recommend that installation be based on the set distance.

Wiring Considerations

AND/OR Connections for Proximity Sensors

Model	Type of connection	Connection	Description
DC 2-Wire	AND (series connection)	Vs Vs	Keep the number of connected Sensors (N) within the range of the following equation. Vs - N × Vn ≥ Operating load voltage N: Number of Sensors that can be connected Vn: Residual output voltage of Proximity Sensor Vs: Power voltage It is possible, however, that the indicators may not light correctly and error pulses (of approximately 1 ms) may be generated because the rated power supply voltage and current are not supplied to individual Proximity Sensors. Verify that this is not a problem before operation.
	OR (parallel connection)	Vs Vs	Keep the number of connected Sensors (N) within the range of the following equation. $N\times i \leq \text{Load reset current}$ $N: \text{Number of Sensors that can be connected}$ $N: \text{Leakage current of Proximity Sensor}$ $N: \text{Example: When an MY (24-VDC) Relay is used as the load, the maximum number of Sensors that can be connected is 4.}$
AC 2-wire	AND (series connection)	Vs ≥ 100V	<tl-ny, e2k-□my□,="" tl-my,="" tl-t□y=""> The above Proximity Sensors cannot be used in a sereis connection. If needed, connect through relays. <e2e-x□y> For the above Proximity Sensors, the voltage VL that can be applied to the load when ON is V_L = Vs - (Output residual voltage × Number of Sensors), for both 100 VAC and 200 VAC. The load will not operate unless V_L is higher than the load operating voltage. This must be verified before use. When using two or more Sensors in series with an AND circuit, the limit is three Sensors. (Be careful of the VS value in the diagram at left.)</e2e-x□y></tl-ny,>
	OR (parallel connection)	(A) Load Videns symbol	In general it is not possible to use two or more Proximity Sensors in parallel with an OR circuit. A parallel connection can be used if A and B will not be operated simultaneously and there is no need to hold the load. The leakage current, however, will be n times the value for each Sensor and reset failures will frequently occur. ("n" is the number of Proximity Sensors.) If A and B will be operated simultaneously and the load is held, a parallel connection is not possible. If A and B operate simultaneously and the load is held, the voltages of both A and B will fall to about 10 V when A turns ON, and the load current will flow through A causing random operation. When the sensing object approaches B, the voltage of both terminals of B is too low at 10 V and the switching element of B will not operate. When A turns OFF again, the voltages of both A and B rise to the power supply voltage and B is finally able to turn ON. During this period, there are times when A and B both turn OFF (approximately 10 ms) and the loads are momentarily restored. In cases where the load is to be held in this way, use a relay as shown in the diagram at left.

Note: When AND/OR connections are used with Proximity Sensors, the effects of erroneous pulses or leakage current may prevent use. Verify that there are no problems before use.

Model	Type of connection	Connection	Description
DC 3-wire	AND (series connection)	(A) + OUT iL Load Vs	Keep the number of connected Sensors (N) within the range of the following equation. $ \begin{aligned} & \text{iL} + (N-1) \times \text{i} \leq \text{Upper limit of Proximity Sensor control output} \\ & \text{Vs - N} \times \text{Vr} \geq \text{Operating load voltage} \end{aligned} $ $ & \text{N Number of Sensors that can be connected} \\ & \text{Vr. Residual output voltage of Sensor} \\ & \text{Vs. Power supply voltage} \\ & \text{i : Current consumption of Sensor} \\ & \text{iL: Load current} \end{aligned} $ $ & \text{Note: When an AND circuit is connected, the operation of Proximity Sensor B} \\ & \text{causes power to be supplied to Proximity Sensor A, and thus erroneous} \\ & \text{pulses (approximately 1 ms) may be generated in A when the power is} \\ & \text{turned ON. For this reason, take care when the load has a high} \\ & \text{response speed because malfunction may result.} \end{aligned} $
	OR (parallel connection)	Vs	For Sensors with a current output, a minimum of three OR connections is possible. Whether or not four or more connections is possible depends on the model.

Note: When AND/OR connections are used with Proximity Sensors, the effects of erroneous pulses or leakage current may prevent use. Verify that there are no problems before use

Extending Cable Length

The cable of a Built-in Amplifier Sensor can be extended to a maximum length of 200 m with each of the standard cables (excluding some models).

For Separate Amplifier Sensors (E2C-EDA, E2C, E2J, E2CY), refer to the specific precautions for individual products.

Bending the Cable

If you need to bend the cable, we recommend a bend radius that is at least 3 times the outer diameter of the cable (with the exception of coaxial and shielded cables).

Cable Tensile Strength

In general, do not subject the cable to a tension greater than that indicated in the following table.

Cable diameter	Tensile strength
Less than 4 mm	30 N max.
4 mm min.	50 N max.

Note: Do not subject a shielded cable or coaxial cable to tension.

Separating High-voltage Lines


Using Metal Conduits

If a power line is to be located near the Proximity Sensor cable, use a separate metal conduit to prevent malfunction or damage. (Same for DC models.)


Example of Connection with S3D2 Sensor Controller

DC 2-Wire Sensors

Using the S3D2 Sensor Controller



Connecting to a Relay Load




Note: DC 2-Wire Sensors have a residual voltage of 3 V. Check the operating voltage of the relay before use.

The residual voltage of the E2E-XD-M1J-T is 5 V.



switch on the S3D2.





Operating Environment

Water Resistance

Do not use the Sensor in water, rain, or outdoors.

Ambient Conditions

Do not use the Sensor in the following environments.

Doing so may cause malfunction or failure of the Sensor.

- To maintain operational reliability and service life, use the Sensor only within the specified temperature range and do not use it outdoors.
- The Sensor has a water resistant structure, however, attaching a cover to prevent direct contact with water will help improve reliability and prolong product life.
- Avoid using the Sensor where there are chemical vapors, especially strong alkalis or acids (nitric acid, chromic acid, or hot concentrated sulfuric acid).

•Maintenance and inspection

Periodic Inspection

To ensure long-term stable operation of the Proximity Sensor, inspect for the following on a regular basis. Conduct these inspections also for control devices.

- Shifting, loosening, or deformation of the sensing object and Proximity Sensor mounting
- Loosening, bad contact, or wire breakage in the wiring and connections
- 3. Adherence or accumulation of metal powder
- 4. Abnormal operating temperature or ambient conditions
- 5. Abnormal indicator flashing (on setting indicator types)

Disassembly and Repair

Do not under any circumstances attempt to disassemble or repair the product.

Quick Failure Check

You can conveniently check for failures by connecting the E39-VA Handy Checker to check the operation of the Sensor.



Read and Understand This Catalog

Please read and understand this catalog before purchasing the products. Please consult your OMRON representative if you have any questions or comments

Warranty and Limitations of Liability

WARRANTY

OMRON's exclusive warranty is that the products are free from defects in materials and workmanship for a period of one year (or other period if specified) from date of sale by OMRON.

OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, REGARDING NON-INFRINGEMENT, MERCHANTABILITY, OR FITNESS FOR PARTICULAR PURPOSE OF THE PRODUCTS. ANY BUYER OR USER ACKNOWLEDGES THAT THE BUYER OR USER ALONE HAS DETERMINED THAT THE PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE. OMRON DISCLAIMS ALL OTHER WARRANTIES, EXPRESS OR IMPLIED.

LIMITATIONS OF LIABILITY

OMRON SHALL NOT BE RESPONSIBLE FOR SPECIAL, INDIRECT, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS, OR COMMERCIAL LOSS IN ANY WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED ON CONTRACT, WARRANTY, NEGLIGENCE, OR STRICT LIABILITY.

In no event shall responsibility of OMRON for any act exceed the individual price of the product on which liability is asserted.

IN NO EVENT SHALL OMRON BE RESPONSIBLE FOR WARRANTY, REPAIR, OR OTHER CLAIMS REGARDING THE PRODUCTS UNLESS OMRON'S ANALYSIS CONFIRMS THAT THE PRODUCTS WERE PROPERLY HANDLED, STORED, INSTALLED, AND MAINTAINED AND NOT SUBJECT TO CONTAMINATION, ABUSE, MISUSE, OR INAPPROPRIATE MODIFICATION OR REPAIR.

Application Considerations

SUITABILITY FOR USE

OMRON shall not be responsible for conformity with any standards, codes, or regulations that apply to the combination of products in the customer's application or use of the product.

At the customer's request, OMRON will provide applicable third party certification documents identifying ratings and limitations of use that apply to the products. This information by itself is not sufficient for a complete determination of the suitability of the products in combination with the end product, machine, system, or other application or use.

The following are some examples of applications for which particular attention must be given. This is not intended to be an exhaustive list of all possible uses of the products, nor is it intended to imply that the uses listed may be suitable for the products:

- Outdoor use, uses involving potential chemical contamination or electrical interference, or conditions or uses not described in this catalog.
- Nuclear energy control systems, combustion systems, railroad systems, aviation systems, medical equipment, amusement machines, vehicles, safety
 equipment, and installations subject to separate industry or government regulations.
- Systems, machines, and equipment that could present a risk to life or property.

Please know and observe all prohibitions of use applicable to the products.

NEVER USE THE PRODUCTS FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCT IS PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

Disclaimers

CHANGE IN SPECIFICATIONS

Product specifications and accessories may be changed at any time based on improvements and other reasons.

It is our practice to change model numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifications of the product may be changed without any notice. When in doubt, special model numbers may be assigned to fix or establish key specifications for your application on your request. Please consult with your OMRON representative at any time to confirm actual specifications of purchased product.

DIMENSIONS AND WEIGHTS

Dimensions and weights are nominal and are not to be used for manufacturing purposes, even when tolerances are shown.

ERRORS AND OMISSIONS

The information in this catalog has been carefully checked and is believed to be accurate; however, no responsibility is assumed for clerical, typographical, or proofreading errors, or omissions.

PERFORMANCE DATA

Performance data given in this catalog is provided as a guide for the user in determining suitability and does not constitute a warranty. It may represent the result of OMRON's test conditions, and the users must correlate it to actual application requirements. Actual performance is subject to the OMRON Warranty and Limitations of Liability.

PROGRAMMABLE PRODUCTS

OMRON shall not be responsible for the user's programming of a programmable product, or any consequence thereof.

COPYRIGHT AND COPY PERMISSION

This catalog shall not be copied for sales or promotions without permission.

This catalog is protected by copyright and is intended solely for use in conjunction with the product. Please notify us before copying or reproducing this catalog in any manner, for any other purpose. If copying or transmitting this catalog to another, please copy or transmit it in its entirety.

2007.12